


OFFICE USE ONLY
Log No. 70664
Permit No. 31590
Basin 175A



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32825

1. OWNER LARRY DOWERS ADDRESS AT WELL LOCATION 1 MILE EAST OF MILE MARK 24 ON HWY 375
MAILING ADDRESS HC 72 Box 07-809 FISH LAKE VALLEY 89010

2. LOCATION NE 1/4 NW 1/4 Sec 19 T 2 N/S R 53 E NYE County
PERMIT NO. 31590 DLE Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	2	2
BEN CLY		2	6	4
SAND & SMALL GRAVEL		6	21	15
WHITE CLY		21	34	13
SMALL GRAVEL & COARSE SAND		34	108	74
BEN CLY		108	110	2
BEN CLY WITH GRAVEL STRINGS	X	110	172	62
SMALL GRAVEL	X	172	210	38
MOSTLY CLY SOME SAND STRINGS		210	270	60
COARSE GRAVEL	X	270	290	20
BEN CLY		290	305	15
SMALL GRAVEL	X	305	318	13
BEN CLY & GRAVEL MIXED		318	335	17
GRAVEL & COARSE SAND	X	335	407	72
MOSTLY CLY SOME GRAVEL STRINGS		407	420	13

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)
From 22 Inches 0 Feet To 420 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	45	.250	72	420

Perforations:
Type perforation Johnson A/C SCREEN
Size perforation 7/8 0.50

From 170 feet to 210 feet
From 270 feet to 290 feet
From 305 feet to 315 feet
From 335 feet to 405 feet
From.....feet to.....feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 420 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 68 °F Quality GOOD

Date started 1-26, 1998
Date completed 2-11, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1000+	NA	15 HRS

TAKE 20 SEC'S AFTER AIR TURNED FOR STATIC WATER LEVEL TO REACH 134' FROM 420 AIR LIFT.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYTEK DRILLING CO. INC. Contractor
Address 2220 STONE DRIVE Contractor
RENO NEVADA 89511

Nevada contractor's license number issued by the State Contractor's Board 024521A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442

Signed Thomas M. Blain
By driller performing actual drilling on site or contractor
Date 2-11-98