

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36909

1. OWNER SUE MORROW ADDRESS AT WELL LOCATION 2328 MAIN ST. GENOA, NV  
 MAILING ADDRESS 604 HILLCREST RD CARSON CITY, NV 89703  
 2. LOCATION NE 1/4 SW 1/4 Sec. 9 T. 13 N. R. 19 E. DOUGLAS County  
 PERMIT NO. 17-083-13 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~ 6" of SANDY CLAY THEN OLDS W CLAY		0	40	40
BROKEN VOL DEBRIS W THIN LAYERS OF LT BRWN CLAY		40	100	60
GRY VOL DEBRIS W SOME SML GRVL & SAND		100	140	40
BROKEN GRY VOL X W SMALL GRVLS & SOME SAND		140	180	40

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>180</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 3 x 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

9. WATER LEVEL  
 Static water level 68 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality \_\_\_\_\_

Date started 12/30, 1997  
 Date completed 12/31, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20-25</u>	<u>—</u>	<u>3 Hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC. Contractor  
 Address 75 LEWENS CRK RD Contractor  
CARSON CITY, NEVADA 89704  
 Nevada contractor's license number 13697A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1790  
 Division of Water Resources, the on-site driller  
 Signed Joe Reich  
 By driller performing actual drilling on site or contractor  
 Date 1/6/98