

OFFICE USE ONLY  
 Log No. 70672  
 Permit No. 103  
 Basin.....

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35165

1. OWNER Veg A. ADDRESS AT WELL LOCATION 874 Bronstein Dayton  
 MAILING ADDRESS.....  
 2. LOCATION SW 1/4 SW 1/4 Sec. 28 T 17 N/S R 22 E County Clark  
 PERMIT NO. 19-288-10 Issued by Water Resources Parcel No. Mark Twain Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Shale Clay</u>		<u>1</u>	<u>36</u>	<u>36</u>
<u>Shale</u>		<u>36</u>	<u>72</u>	<u>36</u>
<u>Clay</u>		<u>72</u>	<u>116</u>	<u>40</u>
<u>Dark</u>		<u>116</u>	<u>128</u>	<u>12</u>
<u>Clay, Sand</u>		<u>129</u>	<u>141</u>	<u>12</u>
<u>Shale</u>		<u>141</u>	<u>157</u>	<u>16</u>

8. WELL CONSTRUCTION  
 Depth Drilled 157 Feet Depth Cased 157 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/8 Inches To 157 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>157</u>

Perforations:  
 Type perforation Iron cut  
 Size perforation 3/16 x 60 x 200  
 From 136 feet to 156 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 63  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 65 feet to 157 feet

9. WATER LEVEL  
 Static water level 63 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature e °F Quality Good

Date started 1-23-98, 19\_\_\_\_  
 Date completed 1-25-98, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>50</u>		<u>2 1/2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name John Wiley Contractor  
 Address PO 299 Contractor  
SS, NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed Mark Twain  
 By driller performing actual drilling on site or contractor  
 Date 1-30-98

RECEIVED  
 98 FEB 20 AM 10:20  
 STATE ENGINEERS OFFICE