

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27998

1. OWNER Greg Davies Construction ADDRESS AT WELL LOCATION 1748 Merino Cir Gardnerville NV 89410
 MAILING ADDRESS Gardnerville NV 89410
 2. LOCATION NE 1/4 NE 1/4 Sec 14 T. 12 S R. 20 E Douglas County
 PERMIT NO. 29-550-11 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Coarse Cabbles and Gravels</u>		<u>3</u>	<u>27</u>	<u>24</u>
<u>Black obsidian Gravels</u>		<u>27</u>	<u>56</u>	<u>28</u>
<u>Black Hard Slate</u>		<u>56</u>	<u>130</u>	<u>74</u>
<u>Brown Sandy Clay</u>		<u>130</u>	<u>159</u>	<u>29</u>
<u>Fractured obsidian State and Gravels</u>	<u>xx</u>	<u>159</u>	<u>180</u>	<u>21</u>

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.23</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3 x 3/32
 From 100 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100' feet to 180' feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. 18 P.S.I.
 Water temperature Good °F Quality Cold

Date started 12/21 1997
 Date completed 12/24 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18</u>	<u>40</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat DR. Carson City NV 89706 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael D. Heck
 By driller performing actual drilling on site or contractor
 Date 12/30/97