

OFFICE USE ONLY  
 Log No. 70680  
 Permit No. 107  
 Basin 107

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27949

1. OWNER T. TRAN ADDRESS AT WELL LOCATION 39 WELLINGTON CUTOFF  
 MAILING ADDRESS 907 WATERLOO WELLINGTON, NV 89444  
GARDNERVILLE, NV 89410  
 2. LOCATION NW 1/4 SE 1/4 Sec. 12 T. 10 S. R. 23 E. LYON County  
 PERMIT NO. 010 711 08 NONE  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Muo

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY w SOME SMALL GRVL SAND & FEW COBBLES		0	55	55
SANDY CLAY w LOOSE SAND LAYERS		55	80	25
GRVLY CLAY w GRVL LAYERS		80	120	40
BROKEN VOLCANICS OR VOL DETRITUS		120	160	40

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 50 Feet  
10 3/4 Inches 50 Feet 160 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>0.188</u>	<u>+2</u>	<u>160</u>

Perforations:  
 Type perforation SAWCUT  
 Size perforation 3x 3/32  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 51  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 51 feet to 160 feet

9. WATER LEVEL  
 Static water level 70 feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 140 °F Quality \_\_\_\_\_

Date started 2/10 1998  
 Date completed 2/13 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC Contractor  
 Address 75 LEWERS CRK RD Contractor  
CARSON CITY, NEVADA 89704  
 Nevada contractor's license number issued by the State Contractor's Board 13697A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476  
 Signed Joe Leisek  
 By driller performing actual drilling on site or contractor  
 Date 2/17/98