

OFFICE USE ONLY
 Log No. 70097
 Permit No. W2388T
 Basin 157D
 NOTICE OF INTENT NO. 31921

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Round Mountain Gold Corp. DW-19 ADDRESS AT WELL LOCATION #1 Smoky Valley Mine Road
 MAILING ADDRESS P.O. Box 480
Round Mountain, Nevada 89045

2. LOCATION NE 1/4 SE 1/4 Sec. 24 T 10 N 3 R 43 E Nye County
 PERMIT NO. 63308T Issued by Water Resources Parcel No. --- Subdivision Name ---

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Test Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
White Brown Rock		2	20	18
Sand Gravel, Orange & Tan		20	95	75
White and Brown Rock		95	175	80
Decomposed Granite		175	215	40
White Brown Rock		215	265	50
Decomposed Granite-clay		265	546	281
Clay with Rock		546	553	7
Rock and Clay		553	560	7
Granite, Sand and Clay		560	650	90
Clay, Sand Cobbles		650	664	14
White-Brown Rock, Clay		664	784	120
Clay, Decomposed Granite		784	805	21
N 38.709597				
W 117.093225 NAD27				
RECEIVED 50 JAN 26 AM 10:04 STATE ENGINEER'S OFFICE				
Plugged under NDI 58863				

8. WELL CONSTRUCTION
 Depth Drilled 805 Feet Depth Cased 797 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
28	0	19		
21	19	805		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	58.07	.250	+1	19
14	36.71	.250	+1	395
14	36.71	.250	595	615
Perforations: 36.71 .250 675 695				
Type perforation: 36.71 .250 755 797				
Size perforation: Wire Wrap 50 Slot				
From 395 feet to 595 feet				
From 615 feet to 675 feet				
From 695 feet to 755 feet				
From feet to feet				
From feet to feet				

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 53 feet to 805 feet

9. WATER LEVEL
 Static water level 419 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sargent Irrigation Company Contractor
 Address 9955 North Virginia Street Contractor
Reno, Nevada 89506
 Nevada contractor's license number 0021240 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1789 Division of Water Resources, the on-site driller.
 Signed [Signature] driller performing actual drilling on site or contractor
 Date January 22, 1998

Date started December 11, 1997
 Date completed January 21, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>10</u>	