

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35957

1. OWNER BUREAU OF LAND MANAGEMENT ADDRESS AT WELL LOCATION FY 97 MOUND VALLEY  
 MAILING ADDRESS 3900 EAST IDAHO ELKO, NEVADA 89801 ZUNINO RESERVOIR  
 2. LOCATION NW 1/4 SW 1/4 Sec. 30 T. 30 N/S R. 56 E ELKO County ELKO  
 PERMIT NO. 57772 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
LOAM		0	4	4
CLAY CREAM COLOR		4	30	26
WHITE CLAY		30	70	40
DECOMPOSED GRANITE		70	84	14
LIGHT TAN CLAY		84	109	25
LOOSE DECOMPOSED	X	109	112	3
GRANITE CAVING	X			
LIGHT TAN CLAY		112	184	72
LOOSE DECOM. GRANITE		184	187	3
CLAY		187	194	7
LOOSE DECOM. GRANITE		194	202	8
LIGHT CREAM EOLOR		202	210	9
CLAY				

8. WELL CONSTRUCTION  
 Depth Drilled 210 Feet Depth Cased 210 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
17 Inches 0 Feet 89 Feet  
12 1/4 Inches 89 Feet 210 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.38	250	0	89
6 5/8	17.02	250	+2	210

Perforations:  
 Type perforation STAINLESS STEEL SCREEN  
 Size perforation .50  
 From 180 feet to 210 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 12 3/4" 89'6 5/8 100' Neat Cement XX  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 210 feet

Date started 11-9 1998  
 Date completed 1-27 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
PUMP	10.5		

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FERTIG DRILLING COMPANY Contractor  
 Address P.O. BOX 525 Contractor  
ELKO, NEVADA 89803  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shoule Fertig  
 By driller performing actual drilling of site or contractor  
 Date JANUARY 28, 1998