

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36610

1. OWNER BONNIE SPENCER ADDRESS AT WELL LOCATION BLK E Lot 4
 MAILING ADDRESS H.C. 36-168-15 Green Bar Lane
Elko NV 89501 Lamaille, NV
 2. LOCATION SW 1/4 NW 1/4 Sec. 26 T 33 N/S R 57 E ELKO County
 PERMIT NO. 023-005-004 Parcel No. Pleasant Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other m.w.d.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>loam</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Cemented Gravel</u>		<u>2</u>	<u>8</u>	<u>6</u>
<u>Hard PAN</u>		<u>8</u>	<u>43</u>	<u>35</u>
<u>CLAY</u>		<u>43</u>	<u>50</u>	<u>7</u>
<u>Gravel</u>		<u>50</u>	<u>63</u>	<u>13</u>
<u>CLAY</u>		<u>63</u>	<u>69</u>	<u>9</u>
<u>Cemented Gravel</u>		<u>69</u>	<u>80</u>	<u>11</u>
<u>SOFT SANDSTONE</u>		<u>80</u>	<u>134</u>	<u>54</u>
<u>Gravel</u>	<u>X</u>	<u>134</u>	<u>137</u>	<u>3</u>
<u>CLAY</u>		<u>137</u>	<u>168</u>	<u>31</u>
<u>Hard Rock</u>		<u>168</u>	<u>184</u>	<u>16</u>
<u>CLAY</u>		<u>184</u>	<u>191</u>	<u>7</u>
<u>FACILE ROCK</u>	<u>X</u>	<u>191</u>	<u>220</u>	<u>29</u>

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 0 Feet 220 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>1.88</u>	<u>1</u>	<u>220</u>

 Perforations:
 Type perforation mill slot
 Size perforation 3/16 x 3"
 From 200 feet to 220 feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 220 feet

Date started 10-1, 1997
 Date completed 10-7, 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>35</u>		<u>3.5</u>
<u>APORK</u>			

9. WATER LEVEL
 Static water level 135 feet below land surface
 Artesian flow..... G.P.M..... P.S.I.
 Water temperature Cold °F Quality.....
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FERTIG DRILLING CO Contractor
 Address P.O. Box 525 Contractor
ELKO NV 89501
 Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shoupe Fertig
 By driller performing actual drilling on site or contractor
 Date 10-9-97