WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70715
Permit No.
Basin 104

NOTICE OF INTENT NO. 30018

1. OWNER Ron Weddell
MAILING ADDRESS 477 Conte Dr.
Carson City, NV. 89701

ADDRESS AT WELL LOCATION 2459 Airport Rd.
Carson City, NV. 89701

2. LOCATION SW ¼ NW ¼ Sec. 10 T 15 N/S R 20 E Carson County
PERMIT NO. Issued by Water Resources | Parcel No. 8-251-32 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well is constructed with 4" steel pipe and located in a pit. We measured the depth of the well at 41'. We installed 1½" steel pipe and air-jetted debris from the well to a depth of 53'. We could not advance pipe further because hole would not stay open. Well was blowing coarse sand and fine gravel so we determined that this was bottom of well. Estimated that well was going to require approx. 4.6 cu. ft. of grout. Mixed 5 bags of Portland Type II cement and 35 gallons of water. Pumped cement through tremme pipe from bottom of well to surface. After tremme pipe was removed, hole was topped off. The top of the casing is approximately 5 ft. below ground level.				

Date started 2-11 19 98
Date completed 2-11 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 6' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address 1401 North Roop St. (Contractor)
Carson City, NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Trampe / Dan Trampe
By driller performing actual drilling on site or contractor
Date February 13, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627