

OFFICE USE ONLY  
 Log No. 70740  
 Permit No. 49  
 Basin 3665  
 NOTICE OF INTEREST NO. 38615

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Randy Brown ADDRESS AT WELL LOCATION Antler Rd  
 MAILING ADDRESS 174 Willow Kittridge cy Rd  
Elko NV 89801

2. LOCATION NE 1/4 SE 1/4 Sec. 34 T. 35 N/S R. 55 & Elko County  
 PERMIT NO. 006-108-021 Kittridge Canyon Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Rock's Boulders		0	9	9
SANDSTONE		9	57	48
White SANDSTONE		57	163	106
SAND & Gravel	X	163	165	2
Cemented SAND & Gravel		165	189	24
White SANDSTONE		189	212	23
Loose SANDSTONE	X	212	232	20

40.873176°N  
 115.755663°W  
 NAD 27  
 Deepened by NOI # 64038  
 Date started 9-26 1997  
 Date completed 9-28 1997

8. WELL CONSTRUCTION  
 Depth Drilled 232 Feet Depth Cased 232 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 232 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>232</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3/16 x 2"  
 From 212 feet to 232 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 52  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 52 feet to 232 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FERTIG Drilling co Contractor  
 Address P.O. Box 525 Contractor  
Elko NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board 0031904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shouc Ferguson  
 By driller performing actual drilling on site or contractor  
 Date 9-30-97

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Open</u>	<u>30</u>		<u>3.5</u>