


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 70749
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340.

NOTICE OF INTENT NO. 17342

1. OWNER Mike & Michelene Griffin ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 981 W. Leffner 891 W. Leffner
Pahrump NV 89048

2. LOCATION NW 1/4 NW 1/4 Sec. 28 T 19S N/S R 53E E Nye County
 PERMIT NO. 29-872-01 Bell Vista
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	20	20
brown calache		20	28	8
brown calache		28	43	15
brown calache		43	69	26
brown calache		69	75	6
brown calache	x	75	78	3
brown clay	x	78	84	6
brown calache/gravel	x	84	93	9
brown calache/gravel	x	93	99	6
brown calache/gravel	x	99	110	11
brown calache/gravel	x	110	125	15
brown calache/gravel	x	125	128	3
brown calache/gravel	x	128	140	12

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5/8	3.7	.280	0	140

Perforations:
 Type perforation SAW CUT
 Size perforation .188
 From 100 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 3/10/98 _____ 19____
 Date completed 3/10/98 _____ 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>.5</u>	<u>N/A</u>	<u>.50</u>

Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 3-17-98

