

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 546

1. OWNER John Petroni ADDRESS AT WELL LOCATION Kittridge Canyon  
MAILING ADDRESS 253 maple st # 3 Block 14 Lot 2  
Elko NV Elko, NV

2. LOCATION SW 1/4 NW 1/4 Sec. 33 T. 35 R. 55 E. Elko County  
PERMIT NO. 037-014-002 MUR # 5

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
70 P Soil		0	2	2
cobles		2	15	13
sand stone		15	243	228
Fractured Limestone	X	243	293	50
Limestone		293	305	12

8. WELL CONSTRUCTION

Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 305 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>305</u>

Perforations:  
Type perforation Fee  
Size perforation  
From 275 feet to 295 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 305 feet

RECEIVED  
97 OCT 17 AM 11:12  
WATER RESOURCES DIVISION

Date started Sept 25, 1997  
Date completed Sept 27, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>207</u>	<u>32</u>	<u>2</u>

9. WATER LEVEL  
Static water level 153 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Staco Well Service Contractor  
Address P.O. Box 10 Contractor  
Elko NV  
Nevada contractor's license number issued by the State Contractor's Board 0038169  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
Signed Shan Bennett  
By driller performing actual drilling on site or contractor  
Date 9-30-97