

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12974

1. OWNER Virgil & Bonnie Mink ADDRESS AT WELL LOCATION PROP # 3  
 MAILING ADDRESS PO BOX 3942 BELMONT ESTATES MANLEY RANCH ROAD  
TONOPAH NEV 89049 ROUND MTN NEVADA 89045

2. LOCATION NW 1/4 SW 1/4 Sec. 33 T. 11 N/S R. 43 E. NYE County  
 PERMIT NO. 10-401-07 Parcel No. \_\_\_\_\_ Subdivision Name OSTERHOUDT

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN CLY		0	16	16
GRAVEL		16	19	3
GREEN CLY		19	23	4
SAND		23	25	2
WHITE CLY		25	34	9
SAND		34	36	2
TAN CLY		36	65	29
SMALL GRAVEL		65	72	7
BRN CLY		72	89	17
SMALL GRAVEL		89	93	4
BRN CLY		93	107	14
SMALL GRAVEL		107	111	4
LARGER GRAVEL	X	111	119	8
TAN CLY		119	137	18
SAND & SMALL GRAVEL		137	141	4
<del>TAN CLY</del>		141	155	14
LARGE GRAVEL	X	155	165	10

8. WELL CONSTRUCTION  
 Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 5/8</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>8 3/4</u> Inches	<u>50</u> Feet <u>165</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>72</u>	<u>165</u>

Perforations:  
 Type perforation MILLED  
 Size perforation 3 1/2" - 64 slots PIF  
 From 110 feet to 120 feet  
 From 155 feet to 165 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
X ENVIRO P14L

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 5 feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature COLD °F Quality G.O.O.

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WOYTEK DRILLING CO INC Contractor  
 Address 2220 STOWE DRIVE Contractor  
RENO NEVADA 89511  
 Nevada contractor's license number issued by the State Contractor's Board 024521A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1442  
 Signed Thomas M Harris  
 By driller performing actual drilling on site or contractor  
 Date 10-16-97

Date started 10-15, 19 97  
 Date completed 10-16, 19 97

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>NA</u>	<u>3ARS</u>