WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70803
Permit No.
Basin 209

NOTICE OF INTENT NO. 16433

1. OWNER Robin Gerry
MAILING ADDRESS 874 Del Rey apt 204 Boulder City NV 89005
ADDRESS AT WELL LOCATION Lot #5 Skyline Drive Indian Ridge Subdivision 7 miles north of Caliente

2. LOCATION N/W ¼ S/W ¼ Sec. 10 T. 3 N(S) R. 61 E. Lincoln County
PERMIT NO. — Issued by Water Resources | 13-150-03 Parcel No. | Indian Ridge Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
gravel - Boulders		2	70	68
Clay - boulders		70	83	13
Hard rock		83	200	117
Fractured Rock-sand		200	305	105
Hard Rock		305	330	25

Received MAR 25 1998 NEVADA OFFICE

Date started 3-12-98, 19
Date completed 3-18-98, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14	30	7

8. WELL CONSTRUCTION
Depth Drilled 330 Feet Depth Cased 330 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	330 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	—	.188	0	330

Perforations:
Type perforation Factory
Size perforation 1/8" x 30
From 230 feet to 250 feet
From 270 feet to 290 feet
From 310 feet to 330 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 330 feet

9. WATER LEVEL
Static water level 218 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address PO Box 54 (Contractor)
Hiko NV 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 3-18-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627