

OFFICE USE ONLY  
 Log No. **70838**  
 Permit No. **212**  
 Basin **212**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17371**

1. OWNER Union Pacific c/o uspac/Laidlaw ADDRESS AT WELL LOCATION Union Pacific  
 MAILING ADDRESS 5665 Flatiron Pkwy Railroad Yard  
Boulder, Co 80301

2. LOCATION NE 1/4 NW 1/4 Sec 34 T 20 N R 61 E Clark County  
 PERMIT NO. MO-2587A 139-27-402-008 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE RW-11  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Previously logged for well ETOW-5 (existing 6" well)		0	11.8	11.8
Gravel		11.8	12	0.2
Caliche		12	19	7
Clay		19	30	11

DEEPEMED 6" DIA Well FROM 11.8 FT TO 30' FT

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)  
 From 5 3/4 Inches 11.8 Feet 30 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.0	0.237	0	30

Perforations:  
 Type perforation slotted PVC  
 Size perforation 0.020"  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 6  Neat Cement  
 Placement Method:  Pumped 6-8  Cement Grout  
 Poured Bentonite Seal  Concrete Grout

Gravel Packed:  Yes  No  
 From 8 feet to 30 feet

Date started 12/4 19 97  
 Date completed 12/4 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. **R.S.I.**  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Dan Wilson (Contractor)  
 Address 731 Pilot Road, Suite H  
Las Vegas, NV 89119  
 Nevada contractor's license number 0034757  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 141589  
 Signed Ronald J. Wilson  
 By driller performing actual drilling on site or contractor  
 Date 3-12-98