WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70857
Permit No.
Basin 212

NOTICE OF INTENT NO. 15672

1. OWNER Secon c/o Southland
MAILING ADDRESS 19033 Nr. Valley Hwy, Suite D-104; Kent, WA 98032
ADDRESS AT WELL LOCATION 3575 E. Lake Mead Boulevard

2. LOCATION NE ¼ SE ¼ Sec. 24 T. 20 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 139-24-701-005 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-2
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	0.5	0.5
Silty Sand		0.5	5	4.5
Silty Clay		5	10	5
Clayey Sand		10	15	5
Clay		15	25	10
Clay w/sand + gravel		25	31	6

Date started 12/10, 19~~9~~97
Date completed 12/10, 19~~9~~97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0 Feet	31 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.50	2.0	0.237	0	30

Perforations:
Type perforation Slotted PVC
Size perforation 0.020"
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6'
Placement Method: ☐ Pumped 6-8' ☒ Poured Bentonite Seal
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 31 feet

9. WATER LEVEL
Static water level 18.95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High (Converse Consultants) Contractor
Address 731 Pilot Road Suite H Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed By driller performing actual drilling on site or contractor
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627