WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70882
Permit No.
Basin

NOTICE OF INTENT NO. 37039

1. OWNER: CHRIS GLOVER
MAILING ADDRESS: 1701 Greg Street, Sparks, Nevada 89431
ADDRESS AT WELL LOCATION: #2 Dos Equis Ct., Sparks, Nevada 89436

2. LOCATION: NE ¼ SW ¼ Sec. 17 T. 21N N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-310-39 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Decomposed granite		1	16	15
Gray hard granite		16	26	10
Rusty decomposed granite		26	28	2
Gray hard granite		28	56	28
Weathered granite		56	81	25
Gray granite		81	179	98
Fractured granite (NO WATER)		179	180	1
Gray granite		180	221	41
Fracture (NO WATER)		221	222	1
Gray hard granite		222	257	37
Fracture granite	X	257	290	33
Gray hard granite		290	300	10

Date started 3-9-98, 19
Date completed 3-13-98, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	300 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 255 feet to 295 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 244 feet below land surface
Artesian flow G.P.M. 40+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 16, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627