WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70886
Permit No. 63100
Basin 179

NOTICE OF INTENT NO. 32828

1. OWNER MERLE CARLSON
MAILING ADDRESS 14689 GRANDE RONDE ROAD
ANATONE WASHINGTON 99401

ADDRESS AT WELL LOCATION 17.4 MILES SOUTH ON HWY AR 504 THEN 1/4 MILE WEST.

2. LOCATION NE SE 1/4 SE NE 1/4 Sec. 26 T. 1 N/S R. 46 E. NYE County
PERMIT NO. 63100 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	5	5
LARGE GRAVEL & SAND		5	85	80
YELLOW CLAY		85	90	5
LARGE GRAVEL & SAND	X	90	190	100
CEMENTED SAND STONE		190	204	14
GRAVEL & SAND	Y	204	240	36
SMALL BOLDERS - GOOD ZONE	X	240	280	40
SMALLER GRAVELS & SAND	Y	280	300	20
GRAVEL WITH CLAY STRINGS	Y	300	320	20
MOSTLY CLY SOME GRAVEL STRINGERS	Y	320	340	20
BRN CLY VERY LITTLE GRAVEL		340	380	40
BRN CLAY		380	400	20

TEST HOLE WAS DRILLED TO 400' - PRODUCTION WELL WAS OPENED UP TO 350'.

RECEIVED 98 APR -8 AM 10:22 STATE ENGINEER'S OFFICE

Date started 3-20, 1998
Date completed 3-30, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2000+		20

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
23 Inches	0 Feet	350 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	45.9	.250	+2	350

Perforations:
Type perforation MILLED & JOHNSON AG SCREEN
Size perforation 3" x 1/4 — .050
From 100 feet to 130 MILLED PERF feet
From 130 feet to 310 AG SCREEN feet
From 310 feet to 340 MILLED PERF feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 350 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 65 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WOYTEK DRILL CO. INC. (Contractor)
Address 2220 STOWE DR. (Contractor)
RENO NEVADA 89511

Nevada contractor's license number issued by the State Contractor's Board 024521A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442

Signed Thomas M Harris
By driller performing actual drilling on site or contractor
Date 3-30-98

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627