WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70887
Permit No. 31591
Basin 173A

NOTICE OF INTENT NO. 32827

1. OWNER JANET DOWERS
MAILING ADDRESS HC 72 BOX 07810
DYER NEVADA 89010

ADDRESS AT WELL LOCATION
1 MI SE OF MILE MARKER 25 ON HWY 375

2. LOCATION NE ¼ SW ¼ Sec. 19 T 2 N/S R 53 E NYE County
PERMIT NO. 31591 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN CLY		0	22	22
GRAVEL - LOSS CIR IN THIS ZONE		22	26	4
TAN CLY		26	37	11
SAND & SMALL GRAVEL		37	41	4
TAN CLY		41	63	22
SAND		63	68	5
TAN CLY		68	82	14
TAN CLY SOME GRAVEL STRINGS		82	121	39
GRAVEL		121	124	3
YELLOW CLY		124	141	17
MED GRAVEL & SAND	X	141	180	39
MOSTLY TAN CLY		180	240	60
GRAVEL & SAND SOME CLY	X	240	340	100
STRINGERS THROUGH ZONE				
BROWN CLY		340	360	20
MED SIZE GRAVEL & SAND	X	360	380	20
WHITE CLY		380	400	20
LARGE GRAVEL & COARSE	X	400	440	40
SAND.				

RECEIVED 98 APR 15 AM 10:47 STATE ENGINEERS OFFICE

Date started 2-23, 1998
Date completed 3-4, 1998

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2000+	[illegible]	20 hrs

Well only Air-Lifted - No pump installed to this date - 4-14-98
Leo Woytek

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
23 Inches	0 Feet	440 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.9	.250	+2	440

Perforations:
Type perforation Johnson Ag SCREEN
Size perforation .050
From 140 feet to 180 feet
From 240 feet to 340 feet
From 360 feet to 380 feet
From 400 feet to 440 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 440 feet

9. WATER LEVEL
Static water level 100' feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cool 70°F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WOYTEK DRILLING CO INC
Contractor
Address 2220 STOWE DRIVE
Contractor
RENO NEVADA 89511

Nevada contractor's license number issued by the State Contractor's Board 024521A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442

Signed Thomas M Harris
By driller performing actual drilling on site or contractor

Date 3-4-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627