WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70896
Permit No.
Basin 103

NOTICE OF INTENT NO. 98896

1. OWNER Tony Lancia
MAILING ADDRESS 2612 Sycamore Glen DR
Carson City NV. 89701
ADDRESS AT WELL LOCATION 310 Bullion St.
Dayton NV. 894

2. LOCATION NE ¼ NE ¼ Sec. 9 T. 16 N/S R. 22 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 19-137-07 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	6	6
Course Sands and Gravels		6	45	
Salt Sand Sands/Clay Seams		45	110	
Brown Gummy Clay Strata w/Layers of Sands		110	186	
	xxx	186	200	
Larger ¼ Gravels Obsidian Volcanic Gravels Carring Water				

RECEIVED
98 APR -9 PM 12:08
STATE ENGINEERS OFFICE

Date started 3-30, 1998
Date completed 4-2, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	35	2 HRS

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11¼ Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.05	.188	0	200

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 200 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat DR. Contractor
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Heck
By driller performing actual drilling on site or contractor
Date 4-3-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627