



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9877

1. OWNER Paula Smith ADDRESS AT WELL LOCATION 7090 Iron Mtn Rd
 MAILING ADDRESS Dayton NV Dayton NV

2. LOCATION SE 1/4 SE 1/4 Sec. 7 T. 17 S. R. 23 E. LYON County
 PERMIT NO. 15-325-09 Parcel No. Iron Mtn Ranches Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Brown Clay</u>		<u>3</u>	<u>8</u>	<u>5</u>
<u>1/4 Gravels</u>		<u>8</u>	<u>63</u>	<u>55</u>
<u>Obsidian Sands</u>				
<u>Obsidian Sands</u>		<u>63</u>	<u>110</u>	<u>47</u>
<u>Small Gravels</u>				
<u>Brown Clay</u>		<u>110</u>	<u>120</u>	<u>10</u>
<u>Broken Obsidian</u>	<u>xxx</u>	<u>120</u>	<u>160</u>	<u>40</u>
<u>Gravels Fractures</u>				
<u>Sands of Red Black orange</u>				

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 16.0 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13.23</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. 17 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat Dr. Carson City NV 89706 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Hook
 By driller performing actual drilling of site or contractor
 Date 4-7-98

Date started 4-6, 1998
 Date completed 4-7, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>17</u>	<u>40</u>	<u>3 HRS</u>

RECEIVED
 98 APR -9 PM 12:08
 STATE ENGINEERS OFFICE