WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70911
Permit No. 99
Basin

NOTICE OF INTENT NO. 81424

1. OWNER Doug Pickering
MAILING ADDRESS 8718 Silver Shores
Reno, NV 89506

ADDRESS AT WELL LOCATION 110 Arabian Way
Reno, NV 89506

2. LOCATION SE ¼ NE ¼ Sec 15 T 23 N/S R 18 E Washoe County
PERMIT NO. N/A (Issued by Water Resources) 078-151-04 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top soil		0	4	4
Composed Granite		4	15	11
Soft Granite		15	240	225
Very hard gray granite		240	363	123
Hard gray granite with soft spots		363	455	92

RECEIVED 98 APR 24 AM 10:19 STATE ENGINEER'S OFFICE

Date started April 11, 1997
Date completed May 4, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	10	450	6

8. WELL CONSTRUCTION
Depth Drilled 455 Feet Depth Cased 455 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches		0 Feet	255 Feet
8 3/4 Inches		255 Feet	363 Feet
6 1/8 Inches		363 Feet	455 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	0-188	+1	363
5 9/16	11	0-188	349	455

Perforations:
Type perforation Mill slot & Mechanical
Size perforation 1/8 x 3 @1/8 x 1
From 125 feet to 150 feet
From 243 feet to 263 feet
From 283 feet to 303 feet
From 323 feet to 343 feet
From 390 feet to 432 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 53' feet to 363 feet

9. WATER LEVEL
Static water level 28' feet below land surface
Artesian flow None G.P.M. None P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Miller & Sons Drilling (Contractor)
Address 605 Spice Island Drive (Contractor)
Reno, NV 89507

Nevada contractor's license number issued by the State Contractor's Board 37915

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2067

Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 4-21-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627