WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70912
Permit No.
Basin 028

I

NOTICE OF INTENT NO. 3[illegible]342

1. OWNER MONTY LOYD
MAILING ADDRESS

ADDRESS AT WELL LOCATION SULPHER, NV.

2. LOCATION SW ¼ NW ¼ Sec. 5 T. 34 N/S R. 29 E. Pershing County
PERMIT NO. 52880 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial (Mining) ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
HARD CLAY		1	10	10
CEMENTED GRAVEL COBBLES		10	15	5
BROWN CLAY/GRAVEL		15	100	85
CEMENTED GRAVEL		100	105	5
BROWN CLAY/GRAVEL		105	125	20
CEMENTED GRAVEL		125	130	5
BROWN CLAY/GRAVEL		130	190	60
SOFT BROWN CLAY		190	198	8
FINE GRAVEL/SAND	198	198	200	2
SOFT BROWN CLAY		200	245	45
GRAVEL/CLAY SEAMS	245	245	270	25
BROWN CLAY/GRAVEL SEAM	270	270	300	30
COURSE SAND + GRAVEL		300	335	35
HARD CLAY/GRAVEL SEAM		335	340	5
GREY CLAY/GRAVEL SEAMS		340	350	10
BROWN CLAY/GRAVEL SEAM		350	400	50
HARD CLAY		400	403	3
BROWN CLAY/GRAVEL SEAM		403	410	7

Date started 10/10, 1997
Date completed 1/[illegible], 1998

RECEIVED 98 APR 24 AM 10:03 STATE ENGINEERS OFFICE

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	190	3 HR

8. WELL CONSTRUCTION
Depth Drilled 410 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	400 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	0	400

Perforations:
Type perforation SAW SLOT + MILLS KNIFE
Size perforation 2" x 1/8 2 x 1/8
From 400 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 FT
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 160 feet to 50 feet

9. WATER LEVEL
Static water level 173 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McNINCH DRILLING (Contractor)
Address PO BOX 585 (Contractor)
WMCA, NV.
Nevada contractor's license number issued by the State Contractor's Board 5437
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1712
Signed Mike McNinch (By driller performing actual drilling on site or contractor)
Date 1/9/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627