

OFFICE USE ONLY  
 Log No. 70922  
 Permit No. \_\_\_\_\_  
 Basin 102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26760

1. OWNER T & G Realty ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_ 3460 BUELL  
SILVER SPRINGS NV SILVER SPRINGS NV  
 2. LOCATION NW 1/4 NE 1/4 Sec. 32 T. 18 N. R. 25 E. Lyon County \_\_\_\_\_  
 PERMIT NO. 18-442-06 Parcel No. \_\_\_\_\_ Subdivision Name Lake Side  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other MUD

6. LITHOLOGIC LOG

| Material               | Water Strata                        | From       | To         | Thick-ness |
|------------------------|-------------------------------------|------------|------------|------------|
| <u>GRAY CLAY</u>       |                                     | <u>0</u>   | <u>12</u>  | <u>12</u>  |
| <u>SANDY CLAY</u>      |                                     | <u>12</u>  | <u>26</u>  | <u>14</u>  |
| <u>DARK FINE SAND</u>  |                                     | <u>26</u>  | <u>47</u>  | <u>21</u>  |
| <u>DARK CLAY</u>       |                                     | <u>47</u>  | <u>75</u>  | <u>54</u>  |
| <u>SAND CLAY</u>       |                                     | <u>75</u>  | <u>135</u> | <u>60</u>  |
| <u>Mud Core - Sand</u> | <input checked="" type="checkbox"/> | <u>135</u> | <u>160</u> | <u>25</u>  |

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       | <u>13</u>           | <u>.138</u>             | <u>+2</u>   | <u>160</u> |

Perforations:  
 Type perforation Factory Mill  
 Size perforation 70 x 4 6 Row  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 47 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality Good

Date started 3-12 1998  
 Date completed 3-14 1998

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
|   |        |                               |              |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eldco Exploration Inc Contractor  
 Address 7780 CERRY RD Contractor  
FALLON, NV. 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-17-98