WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

23aac

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70923
Permit No. 93
Basin

NOTICE OF INTENT NO. 37099

1. OWNER STEPHEN & MONICA BOYES
MAILING ADDRESS 8311 Clearwater Drive
Reno, Nevada 89502

ADDRESS AT WELL LOCATION ~~Antelope Valley Road~~ 1550 Destiny Ct.
Reno, Nevada 89506

2. LOCATION NE ¼ NE ¼ Sec. 23 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources
079-470-~~73 857~~ Parcel No.
Antelope Valley Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Fine brown sand		1	8	7
Decomposed granite with brown clay		8	61	53
Brown clay		61	87	26
Soft zone (NO WATER)		87	91	4
Brown sandy clays		91	131	40
Soft zone	X	131	140	9
Brown sandy clay		140	155	15
Brown rusty medium to coarse sands	X	155	163	8

RECEIVED 98 APR 20 PM 12:02 STATE ENGINEER'S OFFICE

Date started 4-13-98, 19
Date completed 4-14-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		

8. WELL CONSTRUCTION
Depth Drilled 163 Feet Depth Cased 163 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	163 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	163

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 118 feet to 158 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 163 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow G.P.M. 20+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Gary C. Helman
By driller performing actual drilling on site or contractor

Date April 16, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627