

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 5961

1. OWNER Cardell Humphrey ADDRESS AT WELL LOCATION North Audrey Ave
 MAILING ADDRESS 1112 Audrey Wy x 27th St
Roseville CA 95661 Lot 7 - BIK 16

2. LOCATION SE 1/4 SE 1/4 Sec. 31 T. 34 N/S R. 55 E EIKO County
 PERMIT NO. 064-016-007 MUR# 9 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay mix Gravel		0	8	8
CLAY		8	38	30
SANDSTONE		38	57	19
CLAY		57	72	15
SOFT SANDSTONE	X	72	76	4
CLAY		76	134	58
SOFT SANDSTONE	X	134	146	13
SAND SANDSTONE	X	146	172	26
Gravel	X			26

8. WELL CONSTRUCTION
 Depth Drilled 172 Feet Depth Cased 172 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 172 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>1.88</u>	<u>0</u>	<u>172</u>

Perforations:
 Type perforation Millslot
 Size perforation 3/4 x 3"

From 142 feet to 162 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 54

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 54 feet to 172 feet

Date started 3. 26, 1998
 Date completed 3. 28, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APGR</u>	<u>34</u>		<u>3.0</u>

9. WATER LEVEL
 Static water level 100' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor
 Address P.O. Box 525 Contractor
EIKO NV 89803

Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shaul C Fertig
 By driller performing actual drilling on site or contractor
 Date 4-10-98

RECEIVED
 03 APR 17 AM 10:26
 STATE ENGINEERS OFFICE