

OFFICE USE ONLY
 Log No. 70926
 Permit No. 49
 Basin
 35959

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.

1. OWNER GLORIA FLORES ADDRESS AT WELL LOCATION HUMBOLDT LANE and WYMAN WAY
 MAILING ADDRESS P.O. Box 1016
EIKO, NV 89803
 2. LOCATION SE 1/4 SW 1/4 Sec. 21 T. 34 N. S. R. 55 E EIKO County
 PERMIT NO. 006-09H-030 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	13	13
GRAVEL	X	13	31	18
Blue CLAY		31	69	38
Cemented GRAVEL		69	71	2
CLAY		71	98	27
Gravel mix SAND	X	98	122	24

8. WELL CONSTRUCTION
 Depth Drilled 122 Feet Depth Cased 122 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 122 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>1.88</u>	<u>+1.5</u>	<u>122</u>

Perforations:
 Type perforation mill slot
 Size perforation 3/16 x 3"
 From 102 feet to 122 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 122 feet

9. WATER LEVEL
 Static water level 13' feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature Cold °F Quality

Date started 3-23, 1998
 Date completed 3-25, 1998

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APORX</u>	<u>300</u>	<u> </u>	<u>3.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FERTIG DRILLING CO Contractor
 Address P.O. Box 525 Contractor
EIKO NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shaul C. Fertig
 By driller performing actual drilling on site or contractor
 Date 4-10-98

RECEIVED
 98 APR 17 AM 10:26
 STATE ENGINEERING OFFICE