

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 70966
 Permit No. 162
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17598

1. OWNER **SAHARA MOBILE HOMES** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **3451 W. FRITZ** **3451 W. FRITZ**
PAHRUMP, NV 89048

2. LOCATION **SW** 1/4 **NE** 1/4 Sec. **24** T **20S** N/S R **52E** E **NYE** County
 PERMIT NO. **28-783-12** **CHARLESTON PARK RANCHOS**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RV
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	63	63
CALICHE	WB	63	74	11
CLAY		74	89	15
CALICHE	WB	89	106	17
CLAY		106	111	5
CALICHE	WB	111	124	13
CLAY		124	140	16

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

12.25 Inches From 0 Feet To 140 Feet

_____ Inches _____ Feet _____ Feet

_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:

Type perforation **FACTORY SAW CUT**

Size perforation **1/8" X 3"**

From 100 feet to 120 feet f

From _____ feet to _____ feet f

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet f

9. WATER LEVEL

Static water level 58 feet below land surf
 Artesian flow _____ G.P.M. P
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Great Basin Drilling Co.** Contractor

Date started 3/30/98, 19____
 Date completed 4/3/98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Address **PO BOX 4220** Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board **30880**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed Thomas D. ... By driller performing actual drilling on-site or contractor
 Date 4/3/98

