WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

in Book

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70970
Permit No.
Basin 162

NOTICE OF INTENT NO. 17311

1. OWNER Margaret Stalk
MAILING ADDRESS Pahrump, NV 89041
ADDRESS AT WELL LOCATION Jefner Street Pahrump, NV 89041

2. LOCATION NE ¼ NE ¼ Sec. 28 T. 19 N/S R. 53E E. Nye County
PERMIT NO. Issued by Water Resources | 29-881-29 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	8	8
Sandy Clay		8	40	32
Calichia		40	43	3
light grey Clay	X	43	78	25
Sandy Clay	X	78	105	27
Sandy grey Clay	X	105	120	15
Sandy brown Clay	X	120	130	10
Calichia	X	130	134	4
Sandy grey Clay	X	134	170	36
Calichia	X	170	173	3
grey Clay	X	173	200	27

Date started 3-23, 1998
Date completed 3-28, 1998

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	0	1/2

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	0	Sch ~~100~~ 40	0	200

Perforations:
Type perforation ~~Factory~~ Saw cut
Size perforation 3/4 x 4"
From feet to feet
From feet to feet
From 140 feet to 200 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 200' feet

9. WATER LEVEL
Static water level 92' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Water Well Service Contractor
Address P.O. Box 3392 Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Jenkins
By driller performing actual drilling on site or contractor
Date

DOWNED
RECEIVED
APR 15 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627