

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 70986  
 Permit No. 63145  
 Basin 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17717

1. OWNER United States Postal Service ADDRESS AT WELL LOCATION 3001 E. Kellogg  
 MAILING ADDRESS 3001 E. Kellogg 3001 E. Kellogg  
Pahrump, NV 89048

2. LOCATION NW 1/4 NW 1/4 Sec. 19 T 21S N/S R 54E E Nye County  
 PERMIT NO. 63145 45-261-16 Green Saddle Ranches  
 issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE Commercial  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>brown clay</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>light brown calache</u>		<u>8</u>	<u>10</u>	<u>2</u>
<u>brown clay</u>		<u>10</u>	<u>20</u>	<u>10</u>
<u>See next line</u>		<u>20</u>	<u>34</u>	<u>14</u>
<u>brown clay/stringer of lt brown calache</u>				
<u>brown clay</u>		<u>34</u>	<u>42</u>	<u>8</u>
<u>See next line</u>		<u>42</u>	<u>50</u>	<u>8</u>
<u>brown clay/stringers brown calache</u>				
<u>grey clay</u>		<u>50</u>	<u>57</u>	<u>7</u>
<u>grey clay</u>	<u>x</u>	<u>57</u>	<u>65</u>	<u>8</u>
<u>See next line</u>	<u>x</u>	<u>65</u>	<u>80</u>	<u>15</u>
<u>brown clay/brown calache strings</u>				
<u>rown clay</u>	<u>x</u>	<u>80</u>	<u>97</u>	<u>17</u>
<u>brown clay</u>	<u>x</u>	<u>97</u>	<u>126</u>	<u>29</u>
<u>light brown clay</u>	<u>x</u>	<u>126</u>	<u>145</u>	<u>19</u>

8. WELL CONSTRUCTION  
 Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 145 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>145</u>

Perforations:  
 Type perforation Saw Cut  
 Size perforation .188

From 105 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 145 feet

9. WATER LEVEL  
 Static water level 57 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature]  
 By driller performing actual drilling on-site of contractor  
 Date 4-15-98

Date started 4/14/98 19\_\_  
 Date completed 4/14/98 19\_\_

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	
	G.P.M.	Draw Down (Feet Below Static) Time (Hours)
<u>.5</u>	<u>na</u>	<u>.50</u>