

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30800

1. OWNER Cecil & Lois Weaver ADDRESS AT WELL LOCATION Lot 17-B Gate of Hercules Acres
 MAILING ADDRESS HL 33 Box 33510 ELy N.V. 89301-9402

2. LOCATION NE 1/4 SE 1/4 Sec 8 T 17 N/S R. 13 E White Pine County
 PERMIT NO. 005-610-17 Parcel No. Gate of Hercules Acres Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay topsoil		0	5	
gravel cobbles con.		5	9	
Sandy Clay		9	41	
gravel	water	41	41.5	
S. Clay		41.5	44	
Clay		44	54	
Sandy Clay		54	58	
gravel clay	water	58	60	
Clay		60	63	
gravel	water	63	67	
Clay		67	75	
gravel		75	76	
Clay		76	78	
gravel	water	78	79	
Clay		79	85	
gravel	water	85	86	
Clay		86	90	
gravel	water	90	91	
Clay		91	95	
gravel	water	95	97	
Clay		97	102	

8. WELL CONSTRUCTION
 Depth Drilled 102 Feet Depth Cased 102 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 Inches 50 Feet 102 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.8</u>	<u>.187</u>	<u>-1</u>	<u>102</u>

Perforations:
 Type perforation mill
 Size perforation 1/8 x 2.5" x 6 row
 From 62 feet to 102 feet
 From 62 feet to 102 feet
 From 62 feet to 102 feet
 From 62 feet to 102 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 102 feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature 60.4 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nathan R. Maynard Contractor
 Address P.O. Box 174 Lund N.V. 89317 Contractor

Date started March 23 1998
 Date completed March 30 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>35</u>	<u>1 hr</u>

Nevada contractor's license number issued by the State Contractor's Board 0022869
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
 Signed Nathan R. Maynard
 By driller performing actual drilling on site or contractor
 Date April 1 - 98