


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **70996**
 Permit No. _____
 Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17708**

1. OWNER **Howard Johnson** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **1771 E. Jeane Pahrump, NV 89048** **1771 E. Jeane**

2. LOCATION **SE 1/4 NW 1/4 Sec. 2 T 21S N/S R 53E E Nye** County _____
 PERMIT NO. _____ Parcel No. **44-841-01** Subdivision Name **Valley View Estates**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sandy Loam		0	2	2
White Calache		2	6	4
grey calache		6	35	29
light brown clay		35	45	10
grey calache		45	60	15
brown calache	x	60	64	4
brown calache/clay	x	64	79	15
light brown clay	x	79	108	29
brown calache	x	108	140	32

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
11	0	140		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **SAW CUT**
 Size perforation **.188**

From	To	Feet	Feet
100	140		

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal **50**

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL
 Static water level **60** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

Date started **4/2/98**, 19____
 Date completed **4/2/98**, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	.5	na	.50

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *Larry Strickland*
 By driller performing actual drilling on-site or contractor

Date **4-3-98**

