


Log No. **71001**

Permit No. _____

Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17723**

1. OWNER **Tiffany and Nate Nordby**
 MAILING ADDRESS **3501 E. Navajo**
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3501 E. Navajo

2. LOCATION **NW 1/4 NE 1/4 Sec. 19 T 21S**
 PERMIT NO. **45-272-16**
 Issued by Water Resources Parcel No.

N/S R 54E E Nye County
Green Saddle Ranches Subdivision Name


3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	2	2
grey clay		2	8	6
brown clay		8	29	21
brown clay		29	38	9
light brown calache		38	50	12
brown clay		50	68	18
light grey clay	x	68	80	12
light brown calache	x	80	83	3
brown calache	x	83	100	17
See next line	x	100	129	29
brwon clay/strings of calache				
brown calache/clay	x	129	140	11



8. WELL CONSTRUCTION

Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **SAW CUT**
 Size perforation **.188**
 From **100** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **140** feet


9. WATER LEVEL

Static water level **68** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048



Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*
 By driller performing actual drilling on-site or contractor

Date **4-8-98**

Date started **4-5-98**, 19____
 Date completed **4-5-98**, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:	
	G.P.M.	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
Draw Down (Feet Below Static)		
.5	na	.50