

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12445

1. OWNER Morton's Flying J ADDRESS AT WELL LOCATION same as owner

MAILING ADDRESS 1000 E Cheyenne Ave. L.V. NV 89030

2. LOCATION Sec 1/4 SE 1/4 Sec 11 T 22 N 2 R 61 E County Clark

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED  
 New Well  
 Replace  
 Abandon  
 Deepen  
 Recondition  
 Other

4. PROPOSED USE  
 Domestic  
 Municipal/Industrial  
 Irrigation  
 Monitor  
 Stock  
 Test  
 Cable  
 Rotary  
 Auger

6. LITHOLOGIC LOG

| Material                  | Water Strata | From      | To        | Thick-ness |
|---------------------------|--------------|-----------|-----------|------------|
| <u>Silt Sand w/Gravel</u> |              | <u>0</u>  | <u>26</u> | <u>26</u>  |
| <u>Clay</u>               |              | <u>61</u> | <u>70</u> | <u>9</u>   |

8. WELL CONSTRUCTION

| Depth Drilled | Feet | Depth Cased | Feet |
|---------------|------|-------------|------|
| <u>70</u>     |      | <u>70</u>   |      |

HOLE DIAMETER (BIT SIZE)

| Inches   | From     | To        | Feet | Feet |
|----------|----------|-----------|------|------|
| <u>6</u> | <u>0</u> | <u>70</u> |      |      |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>4 1/4</u>       |                     | <u>1/8</u>              | <u>0</u>    | <u>50</u> |

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 250  
 From 50 feet to 70 feet  
 From 70 feet to 70 feet  
 From 70 feet to 70 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal: 42  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 48 feet to 70 feet

9. WATER LEVEL  
 Static water level: 61 feet below land surface  
 Artesian flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature: \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Weber Drilling Services  
 Address: 1210 Sharp Circle, NV 89030  
 Contractor Contactor  
 Nevada contractor's license number 38527

Nevada driller's license number issued by the State Contractor's Board. 2057  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller.

Signed [Signature]  
 Date: 4-10-48  
 Driller performing actual drilling on site or contractor



7. WELL TEST DATA

Date started: \_\_\_\_\_ 19\_\_\_\_  
 Date completed: \_\_\_\_\_ 19\_\_\_\_

| TEST METHOD:               | Bailer | Pump | Air Lift |
|----------------------------|--------|------|----------|
| G.P.M. (Feet Below Static) |        |      |          |
| Time (Hours)               |        |      |          |