WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71071
Permit No. 24[illegible]
Basin [illegible]
NOTICE OF INTENT NO. 38[illegible]

1. OWNER Castle Creek Properties
MAILING ADDRESS 5310 Kitzke Lane
Reno, NV 89511

ADDRESS AT WELL LOCATION 640 Del Monte Lane

2. LOCATION SE 1/4 SE 1/4 Sec. 36 T 19N N/S R 20E/14 E Washoe County
PERMIT NO. WaCo #6096 (Issued by Water Resources) | 40-162-[illegible]61 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other _____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 8" x 137' domestic water well by perforating the casing from 130' to about 18' where we hit the cement seal. We pressure grouted the well and used approximately 3 yards of neat cement at 5.2 gallons of water per sack.				

Date started 2/26/98, 19__
Date completed 2/26/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased 137 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22.36	.188	0	137

Perforations:
Type perforation Mills Knife
Size perforation _____
From 18 feet to 130 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal Total
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 3 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 2-26-98