WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71078
Permit No.
Basin 89 88

NOTICE OF INTENT No. 68046

1. OWNER Dorothy Jamal
MAILING ADDRESS 20655 Cooke
Reno, NV 89511

ADDRESS AT WELL LOCATION
20655 Cooke, Pleasant Valley

2. LOCATION SE 1/4 SE 1/4 Sec. 6 T 17N N/S R 20E E Washoe County
PERMIT NO. _____ Issued by Water Resources
045-562-01 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other _____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we tested the well for gpm. Tested at 2.5 gpm. Pulled the pump and video inspected well. Brushed well casing due to encrustation. Then perforated from 250' to 180'. Jetted out the bottom of the well (approx. 4' to 254). Installed the pump and tested the well at 11.5 gpm with drawdown to pump intake at 231'. The bottom 5' from 245' to 250' was soft and easy to perforate and the next 65' was harder.				

Date started 2/16/97, 19__
Date completed 2/19/97, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
11.5	112	2 hrs

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased 254 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	0	254

Perforations:
Type perforation Mills Knife
Size perforation _____
From 180 feet to 250 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal _____
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 114 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 2-19-98