

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 71087  
 Permit No. \_\_\_\_\_  
 Basin 72B

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 38404

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Sherwin Williams  
 MAILING ADDRESS 101 Prospect Avenue N.W. Cleveland, OH 44115-1075  
 ADDRESS AT WELL LOCATION Intersection of Arkansas St. & Lemon Vly Dr. Reno, NV 89510  
 2. LOCATION NW 1/4 SW 1/4 Sec. 26 T 31N R 19 E Washoe County  
 PERMIT NO. 55940/6020 80-730-01  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	55	55
Clay w/fine sand		55	80	25
Clay		80	90	10
Sand & clay		90	120	30
Sand		120	135	15
Fine sand & clay		135	145	10
Course sand		145	192	47
Clay		192	194	2
Sand & clay		194	262	68
Clay		262	264	2
Sand		264	275	11
Gravel		275	287	12
Clay		287	295	8
Sand & gravel		295	310	15
Sand		310	410	100
Granite Bedrock		410	430	20

8. WELL CONSTRUCTION  
 Depth Drilled 430 Feet Depth Cased 424 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
24 Inches 0 Feet 65 Feet  
19 Inches 65 Feet 430 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<i>SEE</i>				

 Perforations:  
 Type perforation ATTACHED  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 190  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 190 feet to 430 feet

Date started 12/13/97 19\_\_\_\_  
 Date completed 12/17/97 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>189</u>	<u>160.85</u>	<u>24 hrs.</u>

9. WATER LEVEL  
 Static water level 47.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713  
 Signed Jerry G. Tomp  
 By driller performing actual drilling on-site or contractor  
 Date 2-3-98

# Humboldt Drilling & Pump Co., Inc. *S Herwin Williams*

Casing Log	FT.*	Formation - Remarks	
10 3/4" casing			
		3" Gravel Chert + 2-195'	
Cement Grout Seal			
0-190'			
Screen	200	240	
Blank	240	260	
Screen	260	320	
Blank	320	340	
Screen	340	380	
Blank	380	400	
Screen	400	420	
Blank	420	425	
Welded Bull Nose on Bottom			