WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7119
Permit No.
Basin 212

NOTICE OF INTENT NO. 16681

1. OWNER Clark County
MAILING ADDRESS 500 S. Grand Central Pkwy
Las Vegas NV 89106

ADDRESS AT WELL LOCATION 423 Casino Center Blvd

2. LOCATION NE ¼ SW ¼ Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 139-34-201-054 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE 01-A
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	1.5	1.5
LEAN CLAY		1.5	7	5.5
CALICHE		7	8.3	1.3
SANDY CLAY		8.3	15	6.7
CALICHE		15	16	1
CLAY		16	17	1
CALICHE		17	19	2
CLAY		19	20	1
CALICHE		20	23.5	3.5
LEAN CLAY		23.5	35	11.5
CALICHE		35	37.5	2.5
LEAN CLAY		37.5	45	7.5
CALICHE		45	50	5

Date started JAN 14, 19 98
Date completed JAN 14, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	50 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.157	0	50

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 5 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-2'/2-4' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 4 feet to 50 feet

9. WATER LEVEL
Static water level 8.62 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson (Converse Consult)
Contractor
Address 731 Pilot Rd Ste H
Contractor
Las Vegas NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed Don Wilson
By driller performing actual drilling on site or contractor
Date 4/13/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627