



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 15886

1. OWNER CLARK COUNTY ADDRESS AT WELL LOCATION 423 CASINO CENTER BLVD  
 MAILING ADDRESS 500 S. GRAND CENTRAL PKWY LAS VEGAS NV 89106  
 2. LOCATION NE 1/4 SW 1/4 Sec. 34 T 20 N R. 6 E CLARK County  
 PERMIT NO. 139-24-201-054 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE B-A  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	1	1
CLAYEY SAND		1	3	2
SANDY CLAY		3	6	3
CALICHE		6	8.5	2.5
LEAN CLAY		8.5	13	4.5
CALICHE		13	14	1
FAT CLAY		14	17	3
CALICHE		17	24.5	7.5
SANDY CLAY		24.5	31	6.5
CLAYEY SAND		31	33.5	2.5
CALICHE		33.5	37.5	4
SANDY CLAY		37.5	46.5	9
CALICHE		46.5	48.5	2
SILTY SAND		48.5	49.5	1
LEAN CLAY		49.5	67	17.5
SILTY SAND		67	69.5	2.5
SANDY CLAY		69.5	72	2.5
CALICHE		72	73	1
SANDY CLAY		73	80	7

8. WELL CONSTRUCTION  
 Depth Drilled 80 Feet Depth Cased 78 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 80 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.256	0	78

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.020  
 From 38 feet to 78 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-30/30-35' BENTONITE  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 35 feet to 80 feet

9. WATER LEVEL  
 Static water level 9.06 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name THOMAS HIGH (CONVERSE CONS)  
 Address 731 Pilot Rd Sta H LAS VEGAS NV 89119  
 Nevada contractor's license number issued by the State Contractor's Board 0034757  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller M1869  
 Signed Thomas High  
 By driller performing actual drilling on site or contractor  
 Date 4/13/98

Date started JAN 22 1998  
 Date completed JAN 23 1998

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)