



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15685

1. OWNER CLARK COUNTY ADDRESS AT WELL LOCATION 402 S. 3RD ST.
 MAILING ADDRESS 500 S. GRAND CENTRAL PKWY
LAS VEGAS NV 89106

2. LOCATION SE 1/4 NW 1/4 Sec. 34 T. 20 N(S)R. 61 E. CLARK County
 PERMIT NO. 139-34-210-057
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE B-1
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT/FILL		0	1	1
SILTY SAND		1	4	3
FAT CLAY		4	11	7
LEAN CLAY		11	15	4
CALICHE		15	23.5	8.5
SANDY CLAY		23.5	27	3.5
CLAYEY SAND		27	30.5	3.5
SANDY CLAY		30.5	38	7.5
CALICHE		38	40	2
SANDY CLAY		40	43	3
CALICHE		43	46.5	3.5
SANDY CLAY		46.5	52	5.5

8. WELL CONSTRUCTION
 Depth Drilled 52 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 52 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.157	0	50

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.020
 From 5 feet to 50 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0.2' / 2-4' BENTONITE Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 4 feet to 52 feet

9. WATER LEVEL
 Static water level 11.0 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started JAN 15 19 98
 Date completed JAN 15 19 98

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DON WILSON (CONVERSE CONS) Contractor
 Address 731 PIONEER RD SU 4 Contractor
LAS VEGAS NV 89119
 Nevada contractor's license number 0034757
 issued by the State Contractor's Board
 Nevada driller's license number issued by the M1589
 Division of Water Resources, the on-site driller
 Signed Don Wilson
 By driller performing actual drilling on site or contractor
 Date 4/13/98