

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71166
 Permit No. 36994
 Basin 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36994

1. OWNER WILSON TALBOTT ADDRESS AT WELL LOCATION 3400 JENNA WAY
 MAILING ADDRESS 3325 MT ROSE HWY RENO NV 89511 RENO NV 89511
 2. LOCATION SW 1/4 NE 1/4 Sec 30 T 18 N/S R 20 E WASHOE County
 PERMIT NO. 49371 41 GOVT HOMESITES Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other M.U.D.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
THIN SANDY LOAM (2")				
THEN SAND W MINOR GRVLS		0	5	5
SANDY GRVLS W BLERS		5	50	45
Vol BLRS W SAND + GRVLS		50	100	50
SAME W SOME DG		100	300	200
SAME AS 100-300 W MINOR CLAYS IN S + GRVLS	X	300	400	100

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 100 Feet
11 Inches 100 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>400</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 3X 3/32
 From _____ feet to _____ feet
 From 300 feet to 320 feet
 From 340 feet to 360 feet
 From 380 feet to 400 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 400 feet

9. WATER LEVEL
 Static water level 295 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COND. °F Quality _____

Date started 2/19 1998
 Date completed 3/3 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>—</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CRT RD Contractor
WASHOE VALLEY, NV 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1790
 Division of Water Resources, the on-site driller.
 Signed Joe Leiseh
 By driller performing actual drilling on site or contractor
 Date 3/31/97

RECEIVED
 98 APR -7 AM 10:32
 STATE ENGINEERS OFFICE