

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32698

1. OWNER J + P MURPHY ADDRESS AT WELL LOCATION 400 STEPTOE WASHOE VALLEY
 MAILING ADDRESS 295 BELLUVE WASHOE VALLEY 89701 89701
 2. LOCATION SW 1/4 SE 1/4 Sec 23 T. 16 N. R. 19 E. WASHOE County
 PERMIT NO. 05520138 BAER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	1	1
DG W THIN SMALL X GRVLS + THIN GRY CLAYS		1	98	97
DARK GRY TO BLACK CLAY, SLIGHTLY FAT		98	101	3
FINE BLK SANDS X + MIXED DG W AB QTK XTLS		101	120	19
DG CLEAN W AB WT QTK XTLS	X	120	130	10

RECEIVED
 98 APR -7 AM 10:32
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 130 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>0.188</u>	<u>+4</u>	<u>130</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 3X 2/32
 From _____ feet to _____ feet
 From 101 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 101
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 101 feet to 130 feet

9. WATER LEVEL
 Static water level +3 feet below land surface
 Artesian flow YES ± 6 G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality ?

Date started 1/26 1998
 Date completed 1/28 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>	<u>—</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CRK RD Contractor
WASHOE VALLEY 89701
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, on-site driller 1790
 Signed Joe Reisk
 By driller performing actual drilling on site or contractor
 Date 3/26/98