WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71140
Permit No.
Basin 101

NOTICE OF INTENT NO. 37399

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S ALLEN RD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
5990 SARA WAY

2. LOCATION SE 1/4 NW 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources | 008-172-42 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLACK SAND	0	0	10	10
BLACK CLAY		10	20	10
BLACK SAND		20	30	10
BLACK CLAY		30	38	8
BLACK SAND	X	38	58	20

RECEIVED
98 APR -3 AM 10:09
STATE ENGINEERS OFFICE

Date started 3/10/98, 19__
Date completed 3/11/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 58 Feet Depth Cased 58 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	58	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	58

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 52 feet to 56 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: BENTONITE
[X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 10.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed (By driller performing actual drilling on-site or contractor)
Date 4/2/98