

OFFICE USE ONLY
 Log No. 71175
 Permit No. _____
 Basin 72A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31893

1. OWNER J.C. Penned Co ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1111 STEAD Blvd Reno _____
NU 89509 _____
 2. LOCATION SW 1/4 SE 1/4 Sec 31 T 21 N 19 E _____
 PERMIT NO. OID MS# 273 _____
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other ANALOG

6. LITHOLOGIC LOG MW #4 = DN

Material	Water Strata	From	To	Thick-ness
<u>ON 10/1/97</u>				
<u>I FOUND THE</u>				
<u>WELL TO BE IN</u>				
<u>GOOD CONDITION</u>				
<u>AFTER REMOVING</u>				
<u>THE TOP CAP I THEN</u>				
<u>OVERCULLED THE CASING</u>				
<u>TO 26' I THEN</u>				
<u>PRESSURE GRANTED</u>				
<u>FROM 26' TO THE</u>				
<u>SURFACE</u>				

8. WELL CONSTRUCTION
 Depth Drilled 26 Feet Depth Cased N/A Feet
 HOLE DIAMETER (BIT SIZE)
 From 10" To 0 Feet 26 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>SAH #40</u>	<u>PVC</u>	<u>0</u>	<u>26</u>

 Perforations:
 Type perforation FACTORY
 Size perforation 1020
 From 6 feet to 26 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 26 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From N/A feet to N/A feet

Date started 10/1/97 1997
 Date completed 10/1/97 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>N/A</u>		

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ANDRESEN Exploration Drilling Contractor
 Address 1635 BELFORD Rd Contractor
RENO NV 89509
 Nevada contractor's license number 34525
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site of contractor
 Date 11/1/97