WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71183
Permit No.
Basin 107

NOTICE OF INTENT NO. 30530

1. OWNER David Prusch
MAILING ADDRESS 859 Hwy 395 Gardnerville Nv. 89410
ADDRESS AT WELL LOCATION Buckskin Mine Smith Valley

2. LOCATION NE ¼ SW ¼ Sec. 19 T. 13 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG MW#2

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| I Found the well to be in Good Condition. After Removing the Monument I then Put Drill Rod down Casing And Knocked out bottom of Casing. I then Pressure Grouted Hole to Surface | | | | |
| We used 5 bags of Cement. | | | | |

Date started 1-22, 1998
Date completed 1-22, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled N/A Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| N/A Inches | N/A Feet | N/A Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | SCH 40 | PVC | 0' | 45' |
| | | | | |

Perforations:
Type perforation Factory
Size perforation .020
From 30' feet to 45' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 45'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anderson Exploration Drilling (Contractor)
Address 1635 Bilford Rd Reno, NV 89509 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/26/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627