WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71195
Permit No.
Basin 101

NOTICE OF INTENT NO. 37403

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S. ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
1895 PATTI, Fallon

2. LOCATION NW 1/4 NW 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
APN not available Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [✓] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN SAND		0	15	15
BRN CLAY		15	18	3
BROWN SAND		18	25	7
BROWN CLAY		25	30	5
GREY SAND		30	35	5
BROWN CLAY		35	40	5
BROWN SAND	X	40	55	15

RECEIVED
98 MAY -5 AM 10:47
STATE ENGINEER'S OFFICE

Date started 4/2/98, 19__
Date completed 4/2/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	40	Feet
6 1/4	Inches	40	Feet	55	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	55

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 50 feet to 55 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement/Bentonite [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 9.10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling Corp. Contractor
Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor
FALLON, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed By driller performing actual drilling on-site or contractor
Date 4-29-98