WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71197
Permit No.
Basin 10
NOTICE OF INTENT NO. 37410

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S. ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
5270 CALEB, Fallon

2. LOCATION NW 1/4 SE 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources
APN not available Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [✓] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	15	15
CLAY		15	20	5
SAND		20	40	20
BLACK CLAY		40	46	6
BLACK SAND	X	46	57	11

Date started 4/2/98, 19__
Date completed 4/3/98, 19__

RECEIVED
MAY -5 AM 10:47
STATE ENGINEER'S OFFICE

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/8	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	60	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	60

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 52 feet to 58 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 46
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement Bentonite [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling Corp. Contractor
Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor
FALLON, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed _____ By driller performing actual drilling on-site or contractor
Date 4-29-98