

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 36432

1. OWNER Mark Hansen ADDRESS AT WELL LOCATION 165 McKean's Dr  
MAILING ADDRESS HER 30 Box 30 Spring Creek NV  
Elko NV 89801 Lot 3 BIKC (AKA 170 Sage Lake Dr?)

2. LOCATION S2 1/4 SW 1/4 Sec. 35 T. 35.34 N R. 56 E 91K0 County  
PERMIT NO. 06-310-16-5 Parcel No. Sage Lake Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	2	2
Culiche		2	4	2
Sand		4	107	103
sand stone		107	149	42
water sand	X	149	161	12
sandstone		161	165	

8. WELL CONSTRUCTION  
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
10 Inches 0 Feet 165 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>165</u>

Perforations:  
Type perforation Luc  
Size perforation  
From 140 feet to 160 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 165 feet

9. WATER LEVEL  
Static water level 51 feet below land surface  
Artesian flow G.P.M. P.S.I.  
Water temperature °F Quality

Date started June 25 1997  
Date completed July 25 1997

7. WELL TEST DATA

TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>307</u>	<u>0</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name STACO WELL SERVICE Contractor  
Address P.O. Box 10 Contractor  
ELKO NV 89801

Nevada contractor's license number issued by the State Contractor's Board: 0038169  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1438

Signed Shan Bennett  
By driller performing actual drilling on site or contractor  
Date June 25-97