WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 71199
Permit No.
Basin 180

NOTICE OF INTENT NO. 3[redacted]801

1. OWNER Bill Kingston
MAILING ADDRESS 2283 W. Aultmun Ely NV 89301
ADDRESS AT WELL LOCATION 172 N. Street Parcel No 3 McGill Hwy.

2. LOCATION SE ¼ SE ¼ Sec 25 T 11 N/S R 63 E White Pine County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. Subdivision Name: None

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 16" | |
| gravel cobbles | | 16" | 24' | |
| clay | | 24 | 28 | |
| gravel cobbles | | 28 | 44 | |
| Clay gravel con. | | 44 | 71 | |
| Clay | | 71 | 73 | |
| clay-gravel conglomerate | | 73 | 89 | |
| clay con. | | 89 | 91 | |
| gravel con. | water | 91 | 103 | |
| clay con. | | 103 | 106 | |
| gravel | water | 106 | 123 | |
| clay con. | | 123 | 126 | |
| gravel | water | 126 | 128 | |
| clay con | | 128 | 134 | |
| gravel | water | 134 | 135 | |
| clay con | | 135 | 140 | |

RECEIVED 98 MAY -4 AM 10:58 STATE ENGINEER'S OFFICE

Date started April 4, 1998
Date completed April 24, 1998

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 40 | 4 | 1 hr. |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | 0 Feet | 50 Feet |
| 8 Inches | 50 Feet | 120 Feet |
| 6 Inches | 120 Feet | 140 Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | -1 | 140 |

Perforations:
Type perforation Mill
Size perforation 1/8 x 2.5" x 6 row
From feet to feet
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 91 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board: 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Owen Maynard (By driller performing actual drilling on site or contractor)
Date April 30-98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627