WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71202
Permit No.
Basin 70

NOTICE OF INTENT NO. 36930

1. OWNER Don Meldrum
MAILING ADDRESS P.O. Box 1876
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION
Highway 40 Lot 17

2. LOCATION 1/4 NW 1/4 Sec. 17 T 35N N/S R 37E E Humboldt County
PERMIT NO. (Issued by Water Resources) Parcel No. 13-223-27-33 Subdivision Name Sonoma Ranchos

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Clay		3	60	57
Gravel	x	60	73	13
Clay		73	91	18
Sand & gravel	x	91	123	32

RECEIVED 97 JUL 16 AM 10:08 STATE ENGINEER'S OFFICE

Date started 7/9/97 , 19__
Date completed 7/9/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		1 1/2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 123 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8	Inches	0 Feet	123 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 x 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 7-15-97